

STATE OF CALIFORNIA
CALIFORNIA REGIONAL WATER QUALITY CONTROL BOARD
LOS ANGELES REGION
320 West 4th Street, Suite 200, Los Angeles, California 90013

FACT SHEET
WASTE DISCHARGE REQUIREMENTS
FOR
CALLEGUAS MUNICIPAL WATER DISTRICT
(Salinity Management Pipeline Phase 1E, Hydrostatic Test Project)

NPDES NO. CAG6740014
CI-9391

FACILITY ADDRESS

Along Hueneme Road from Edison Dr. to
Surfside Dr., at the Port Hueneme Beach Park
City of Oxnard and City of Port Hueneme, CA

FACILITY MAILING ADDRESS

2100 Olsen Road
Thousand Oaks, CA 91360

PROJECT DESCRIPTION:

The Calleguas Municipal Water District (The District) discharges hydrostatic test water from the Salinity Management Pipeline Phase 1E Project at Port Hueneme Beach Park. The pipeline will be hydrostatically tested in segments. Discharge from the project site is regulated under General NPDES Permit No. CAG674001 (Order No. R4-2004-0109) which was issued on March 13, 2008. The District submitted a Notice of Intent (NOI) form to continue enrollment under the General NPDES Permit No. CAG674001, Order No. R4-2009-0068, which was adopted by the Board on June 4, 2009. The existing enrollment under Order No. R4-2004-0109 is superseded by this new permit.

VOLUME AND DESCRIPTION OF DISCHARGE:

Up to 0.8 million gallons per day (mgd) of hydrostatic test water will be discharged from the project. The hydrostatic test water will be discharged from the following four outfall locations:

Outfall No.	Location	Latitude	Longitude	Receiving Water
M-001	Bubbling Springs, City of Port Hueneme	34° 08' 32"	119° 11' 25"	Miscellaneous Coastal Stream
M-002	J Street and Hueneme Rd., City of Port Hueneme	34° 08' 50"	119° 11' 10"	Miscellaneous Coastal Stream
M-003	Oxnard Industrial Drain, Oxnard	34° 08' 50"	119° 10' 40"	Miscellaneous Coastal Stream
M-004	City of Oxnard storm drain, Oxnard	34° 08' 50"	119° 09' 59"	Miscellaneous Coastal Stream

The discharge flows into Miscellaneous Ventura Coastal Streams of the Pacific Ocean, a water of the United States. The site location map is shown in Figure 1.

September 8, 2009

APPLICABLE EFFLUENT LIMITATIONS

Based on the information provided in the NPDES Application Supplemental Requirements, the following constituents listed in the Table below have been determined to show reasonable potential to exist in the discharge. The discharge from the outfalls drain to Miscellaneous Ventura Coastal Streams. Therefore, attachment B of the Order is not applicable to this discharge.

This table lists the specific constituents and effluent limitations applicable to the discharge.

Constituents	Units	Discharge Limitations	
		Daily Maximum	Monthly Average
Total Suspended Solids	mg/L	150	50
Turbidity	NTU	150	50
BOD ₅ 20°C	mg/L	30	20
Oil and Grease	mg/L	15	10
Settleable Solids	ml/L	0.3	0.1
Sulfides	mg/L	1.0	---
Residual Chlorine	mg/L	0.1	

FREQUENCY OF DISCHARGE:

The discharge of hydrostatic test water will be intermittent and will last for about two weeks.

REUSE OF WATER:

The reuse of hydrostatic test water at the site was evaluated. It is not feasible to discharge the wastewater to the sanitary sewer system and it is not cost effective to truck the water off-site. The project area lacks landscaped area for irrigation at the time of discharge. Therefore, the hydrostatic test water will be discharged into the storm drain or the springs in accordance with the attached order.

